

COST ESTIMATES FOR 25X1A6a CONCENTER

25X1A6a

Costs for renovation of the parent room area for the [REDACTED] Communications Center are estimated as follows:

<u>ITEM</u>	<u>25X1A6a</u> [REDACTED] <u>COST</u>	<u>U.S. DOLLAR COST</u>
Procurement of paint and labor for painting of room area.	780	104.00
Procurement, construction and installation of wooden partition.	6500	866.67
Procurement and installation of electrical wiring	3275	436.67
Procurement and installation of 4 additional lighting fixtures.	480	64.00
Housing, bedding, installing and exhausting generator.	4200	560.00
Procurement and installation of conduit and grounding strap for the power generator	1975	263.33
Procurement (GFE) of 5 Air Conditioners, each with 15,000 BTU capacity \$264.00 each.		1320.00
Total Cost		\$3614.67

Bricking up or barring of air duct leading into Room 1 of the Proposed Equipment Layout has not been estimated, but it is believed that this item will not exceed \$100.00.